

RESOL Modbus/TCP Configuration

Filename: RESOL_DeltaSol_CS_Plus_ModbusConfig_1.0.0.cbor
ID: RESOL_DeltaSol_CS_Plus
Version: 1.0.0
Build at: 2019-11-25 13:46

Coils (Type 0)

No values defined!

Discrete Inputs (Type 1)

Address	Description	Factor	Unit
0	Sensor 1 defective	1	
1	Sensor 2 defective	1	
2	Sensor 3 defective	1	
3	Sensor 4 defective	1	

Input Registers (Type 3)

Address	Description	Factor	Unit
0	Temperature sensor 1	0.1	°C
1	Temperature sensor 2	0.1	°C
2	Temperature sensor 3	0.1	°C
3	Temperature sensor 4	0.1	°C
4	Pump speed relay 1	1	%
5	Pump speed relay 2	1	%
6	Operating hours relay 1	1	h
7	Operating hours relay 2	1	h
8	UnitType	1	
9	System	1	
10	ErrorMask	1	
11	System time	1	
12	Status mask (bits 16..31)	1	
13	Status mask (bits 0..15)	1	
14	Heat quantity (bits 16..31)	1	Wh
15	Heat quantity (bits 0..15)	1	Wh
16	SW Version	0.01	

Holding Registers (Type 4)

No values defined!