

RESOL Modbus/TCP Configuration

Filename: RESOL_DeltaTherm_FK_ModbusConfig_1.0.0.cbor
ID: RESOL_DeltaTherm_FK
Version: 1.0.0
Build at: 2020-09-21 11:44

Coils (Type 0)

No values defined!

Discrete Inputs (Type 1)

No values defined!

Input Registers (Type 3)

Address	Description	Factor	Unit
0	DeltaTherm FKTemperature sensor 1	0.1	°C
1	DeltaTherm FKTemperature sensor 2	0.1	°C
2	DeltaTherm FKTemperature sensor 3	0.1	°C
3	DeltaTherm FKTemperature sensor 4	0.1	°C
4	DeltaTherm FKPump speed relay 1	1	%
5	DeltaTherm FKPump speed relay 2	1	%
6	DeltaTherm FKMixer open	1	%
7	DeltaTherm FKMixer closed	1	%
8	DeltaTherm FKSystem message	1	
9	DeltaTherm FKDate (bits 16..31)	1	
10	DeltaTherm FKDate (bits 0..15)	1	
11	DeltaTherm FKTime	1	

Holding Registers (Type 4)

No values defined!