

RESOL Modbus/TCP Configuration

Filename: RESOL_DeltaTherm_HC_Mini_ModbusConfig_1.0.0.
ID: RESOL_DeltaTherm_HC_Mini
Version: 1.0.0
Build at: 2018-11-26 19:28

Coils (Type 0)

No values defined!

Discrete Inputs (Type 1)

No values defined!

Input Registers (Type 3)

Address	Description	Factor	Unit
0	Temperature sensor 1	0.1	°C
1	Temperature sensor 2	0.1	°C
2	Temperature sensor 3	0.1	°C
3	Temperature sensor 4	0.1	°C
4	Temperature sensor 5	0.1	°C
5	Pump speed relay 1	1	%
6	Pump speed relay 2	1	%
7	Pump speed relay 3	1	%
8	Pump speed relay 4	1	%
9	Controller output 1	1	%
10	Controller output 2	1	%
11	System date (bits 16..31)	1	
12	System date (bits 0..15)	1	
13	Error mask (bits 16..31)	1	
14	Error mask (bits 0..15)	1	
15	Warning mask (bits 16..31)	1	
16	Warning mask (bits 0..15)	1	
17	Heating_Heating circuit1_Tflowset_C	0.1	°C
18	Heating_Heating circuit1_Operating state	1	
19	Heating_Heating circuit1_Operating mode	1	
20	Heating_Heating circuit1_Boiler starts (bits 16..31)	1	
21	Heating_Heating circuit1_Boiler starts (bits 0..15)	1	

Holding Registers (Type 4)

No values defined!